


# DUCT WRAP WITH KWIKSTRETCH® MARKINGS



## Submittal Sheet

Form No. AH-SS-5

Effective: 11/00

Supersedes, AH-SS-5

Dated 7/97

Submittal Date:

## DESCRIPTION

Knauf Duct Wrap with KwikStretch Markings is a thermal and acoustical insulation blanket made from highly resilient, inorganic glass fibers bonded by a thermosetting resin. It is available unfaced, with a foil-scrim-kraft (FSK) jacket, a metalized polypropylene-scrim-kraft (PSK) jacket, or with white or grey vinyl vapor retarders. Vapor retarders provide a 2" (51 mm) staple flange on one edge, and the factory-applied facing assures uniform quality. KwikStretch Markings on the staple flange (FSK and PSK only) allow for easy and accurate job site measurements.

## APPLICATION

Knauf Duct Wrap with KwikStretch Markings is used as external insulation on commercial or residential heating or air conditioning ducts. It is suitable for the exterior of rectangular or round sheet metal ducts and spaces or surfaces where temperature and condensation must be controlled.

## FEATURES

- Low "k" factor significantly reduces heat gain or loss when applied with proper compression.
- Flexible.
- Lightweight.
- KwikStretch Markings on the FSK and PSK staple flanges.
- Excellent acoustical properties.
- Tough and resilient.

## BENEFITS

- Energy conservation, which lowers operating costs.
- System efficiency increases; energy usage/costs decrease.
- Conforms easily to flat or irregular surfaces.
- Rolls allow for faster installation, lower labor costs.
- Easier, faster measurement of stretch-out lengths.
- Reduces sound transmission through the duct wall.
- Assured condensation control when used with FSK or PSK facings, proper installation and sealed joints, seams and penetrations.
- Resists damage in shipment and during and after installation.

## SPECIFICATION COMPLIANCE

### In U.S.:

- ASTM C 553; Type I, II, III
- ASTM C 795
- ASTM C 1136; Type II\* (FSK and PSK facings only)
- ASTM C 1290
- California Title 24 (installed at 25% compression)
- HH-I-558C; Form B, Type I, Class 7
- MIL-I-24244C
- NFPA 90A and 90B
- NRC Reg. Guide 1.36

\* Replaces HH-B-100B.

### In Canada:

- CAN 4-S102
- CAN/CGSB-51.5M; Type II (FSK facing)
- CAN/CGSB-51.11-92
- CCG Low FS Laminate Cert#GI-141

## TECHNICAL DATA

### Surface Burning Characteristics

- UL/ULC listed.
- Unfaced or composite (insulation, facing and adhesive) does not exceed 25 Flame Spread, 50 Smoke Developed when tested in accordance with ASTM E 84, CAN 4-S102, NFPA 255 and UL 723.

### Temperature Range (ASTM C 411)

- Faced, can be used on ducts operating up to 250°F (121°C).
- Unfaced, up to 350°F (177°C).

### Water Vapor Permeance (ASTM E 96, Procedure A)

- FSK and PSK facings have maximum water vapor permeance of .02 perms.
- Vinyl facings have a maximum water vapor permeance of 1.3 perms.

### Water Vapor Sorption (ASTM C 1104)

- Less than 5% by weight when tested for 96 hours at 120°F (49°C) and 95% relative humidity.

### Corrosiveness (ASTM C 665)

- Will not accelerate corrosion of a steel panel compared to sterile cotton.

### Mold Growth (ASTM C 1338)

- No growth.

### Puncture Resistance (TAPPI Test T803) (Beach Units)

- FSK and PSK: 25

## APPLICATION AND SPECIFICATION GUIDELINES

### Storage

- Protect stored insulation from water damage, construction damage and other abuse.
- If stored outside, proper protection from weather conditions should be provided.

### Preparation

- Install Knauf Duct Wrap with KwikStretch Markings over clean, dry sheet metal ducts. All sheet metal joints and seams must be sealed to prevent air leakage from the duct.

### Application

- Install Duct Wrap with KwikStretch Markings with facing to the outside to obtain specified R-value using a maximum of 25% compression.
- Butt all insulation joints firmly together. Longitudinal seam of the vapor retarder must be overlapped a minimum of 2" (51 mm). A 2" (51 mm) tab is provided for the circumferential seam and must be overlapped.
- Where vapor retarder performance is necessary, all penetrations, joints, seams and damage to the facing should be enclosed/sealed with staples, tape, mastic; or an FSK, PSK, vinyl or foil tape prior to system startup.
- Pressure sensitive tapes should be a minimum 3" (76 mm) wide and be applied with moving pressure using an appropriate sealing tool. Staples should be outward clinch and placed approximately 6" on center.
- Closure systems should have a 25/50 F.H.C. per UL 723.
- For rectangular ducts over 24" (610 mm) wide, secure the insulation to the bottom side of the duct with mechanical fasteners spaced on 18" (457 mm) centers to reduce sag. Care should be taken to avoid overcompressing the insulation with the retaining washer.
- Unfaced Duct Wrap should be overlapped a minimum of 2" (51 mm) and fastened with 4" (102 mm) to 6" (152 mm) nails or skewers placed 4" (102 mm) apart, or secured with a wire or banding system. Care must be taken to avoid damaging the duct wrap.

### Installation Procedures

- Use the table on the back to determine stretch-outs required for the nominal thickness of insulation to limit average compression of the insulation to 25% or less. Use KwikStretch Markings on the FSK or PSK staple flanges to speed measurement of duct wrap.

## NOTES:

The chemical and physical properties of Knauf Duct Wrap with KwikStretch Markings represent typical average values determined in accordance with accepted test methods. The data is subject to normal manufacturing and testing variations. The data is supplied as a technical service and is subject to change without notice. References to numerical flame spread ratings are not intended to reflect hazards presented by these or any other materials under actual fire conditions. Check with your Knauf regional office to assure information is current.

# KNAUF

"This is my insulation."™

**Knauf Fiber Glass GmbH**  
One Knauf Drive  
Shelbyville, IN 46176  
(800) 825-4434  
FAX (317) 398-3675

Knauf has regional offices throughout the U.S. and Canada. For the number of the nearest office, call (800) 825-4434.

# DUCT WRAP

## WITH KWIKSTRETCH® MARKINGS

### INSERTION LOSS (REDUCTION OF SOUND TRANSMITTED THROUGH DUCT WALL) (SOUND AND VIBRATION DESIGN AND ANALYSIS, NATIONAL ENVIRONMENTAL BALANCING BUREAU, 1994)

Duct Dimensions	Sheet Metal	Duct Wrap		Insertion Loss, dB/LF of Duct						
		Nominal Thickness	Nominal Density	63Hz	125Hz	250Hz	500Hz	1000Hz	2000Hz	4000Hz
12" x 12" (305 mm x 305 mm)	24 GA	1½" (38 mm)	.75 PCF (12 kg/m³)	.6	.6	.6	.7	7.4	14.2	20.9
24" x 12" (610 mm x 305 mm)	24 GA	1½" (38 mm)	.75 PCF (12 kg/m³)	.6	.6	.6	.7	7.4	14.2	20.9
48" x 12" (1219 mm x 305 mm)	22 GA	1½" (38 mm)	.75 PCF (12 kg/m³)	.5	.5	.5	.6	7.4	14.1	20.9
24" x 24" (610 mm x 610 mm)	22 GA	1½" (38 mm)	.75 PCF (12 kg/m³)	.5	.5	.5	.6	7.4	14.1	20.9
24" x 12" (610 mm x 305 mm)	26 GA	1½" (38 mm)	.75 PCF (12 kg/m³)	.8	.8	.8	.8	7.5	14.2	21.0
24" x 8" (610 mm x 203 mm)	26 GA	2" (51 mm)	.75 PCF (12 kg/m³)	1.0	1.0	1.0	3.6	10.4	17.1	23.9

### R-VALUES @ 75 °F MEAN TEMPERATURE

Density	Thickness	Out-Of-Package R-Value	Installed R-Value (at 25% Compression)
.75 PCF (12 kg/m³)	1½" (38 mm)	5.1	4.2
	2" (51 mm)	6.8	5.6
	2¾" (56 mm)	7.4	6.0
	2½" (64 mm)	8.5	7.0
	3" (76 mm)	10.2	8.4
1.0 PCF (16 kg/m³)	1½" (38 mm)	5.6	4.5
	2" (51 mm)	7.4	6.0
1.5 PCF (24 kg/m³)	1½" (38 mm)	6.1	4.8
	2" (51 mm)	8.2	6.4

### FORMS AVAILABLE

Density	Thickness	Width	Length	Facing
.75 PCF (12 kg/m³)	1½" (38 mm)	48" (1219 mm)	100' (30.48 m)	FSK, PSK, vinyl, unfaced
	2" (51 mm)		75' (22.86 m)	
	2¾" (56 mm)		75' (22.86 m)	FSK
	2½" (64 mm)		75' (22.86 m)	FSK
	3" (76 mm)		50' (15.24 m)	FSK, PSK, vinyl
1.0 PCF (16 kg/m³)	1½" (38 mm)		100' (30.48 m)	FSK, PSK, unfaced
	2" (51 mm)		75' (22.86 m)	unfaced
1.5 PCF (24 kg/m³)	1½" (38 mm)		40' (12.19 m)	FSK, PSK
	2" (51 mm)		40' (12.19 m)	

### THERMAL EFFICIENCY (ASTM C 177)

Mean Temperature	0.75 PCF		1.0 PCF		1.5 PCF	
	k	k (SI)	k	k (SI)	k	k (SI)
50° F (10°C)	.28	.040	.26	.037	.23	.033
75° F (24°C)	.29	.042	.27	.039	.24	.035
100° F (38°C)	.31	.045	.29	.042	.26	.037
125° F (52°C)	.33	.048	.31	.045	.28	.040
150° F (66°C)	.36	.052	.34	.049	.31	.045
175° F (80°C)	.39	.056	.37	.053	.33	.048
200° F (93°C)	.43	.063	.40	.058	.36	.052

### STRETCH-OUTS

Labeled Thickness	Installed Compressed Thickness	Round	Square	Rectangular
1½" (38 mm)	1⅞" (29 mm)	P+9½" (241 mm)	P+8" (203 mm)	P+7" (178 mm)
2" (51 mm)	1½" (38 mm)	P+12" (305 mm)	P+10" (254 mm)	P+8" (203 mm)
2¾" (56 mm)	1⅞" (42 mm)	P+13" (330 mm)	P+11" (279 mm)	P+8½" (216 mm)
2½" (64 mm)	1⅞" (48 mm)	P+14½" (368 mm)	P+12½" (318 mm)	P+9½" (241 mm)
3" (76 mm)	2¼" (57 mm)	P+17" (432 mm)	P+14½" (368 mm)	P+11½" (292 mm)

P=Perimeter of duct to be installed.

### CONDENSATION CONTROL RECOMMENDED MINIMUM INSTALLED R-VALUES FOR CONDENSATION CONTROL ON FLAT SURFACES. SURFACE EMITTANCE: 0.2 (AGED ALUMINUM FOIL OR GALVANIZED SHEET METAL).

RH %	Operating Temperature:														
	45°F (7°C)					55°F (13°C)					60°F (18°C)				
	Ambient Temperature (°F)					Ambient Temperature (°F)					Ambient Temperature (°F)				
	70	80	90	100	110	70	80	90	100	110	70	80	90	100	110
60	2.2 <sup>1</sup>	3.3 <sup>1</sup>	4.3 <sup>2</sup>	4.3 <sup>2</sup>	5.4 <sup>3</sup>	1.1 <sup>1</sup>	2.2 <sup>1</sup>	3.3 <sup>1</sup>	3.3 <sup>1</sup>	4.3 <sup>2</sup>	1.1 <sup>1</sup>	1.1 <sup>1</sup>	2.2 <sup>1</sup>	3.3 <sup>1</sup>	4.3 <sup>2</sup>
70	3.3 <sup>1</sup>	5.4 <sup>3</sup>	6.5 <sup>4</sup>	7.6 <sup>5</sup>	—	1.1 <sup>1</sup>	3.3 <sup>1</sup>	4.3 <sup>2</sup>	6.5 <sup>4</sup>	6.5 <sup>4</sup>	1.1 <sup>1</sup>	1.1 <sup>1</sup>	3.3 <sup>1</sup>	5.4 <sup>3</sup>	6.5 <sup>4</sup>
80	7.0 <sup>4</sup>	—	—	—	—	3.3 <sup>1</sup>	6.5 <sup>4</sup>	—	—	—	2.2 <sup>1</sup>	3.3 <sup>1</sup>	6.5 <sup>4</sup>	—	—
90	—	—	—	—	—	—	—	—	—	—	6.5 <sup>4</sup>	—	—	—	—

<sup>1</sup> All Duct Wrap Products

<sup>2</sup> 0.75 PCF, 2" and greater; 1.0 PCF, 1½" and greater;

1.5 PCF, 1½" and greater

<sup>3</sup> 0.75 PCF, 2" and greater; 1.0 PCF, 2"; 1.5 PCF, 2"

<sup>4</sup> 0.75 PCF, 2½" and greater

<sup>5</sup> 0.75 PCF, 3"